



Aalborg Universitet

AALBORG UNIVERSITY  
DENMARK

## A Vibrotactile Interface to Motivate Movement for Children with Severe to Profound Disabilities

Manresa-Yee, Cristina ; Morrison, Ann; Larsen, Jeppe Veirum; Varona, Javier

*Published in:*

Proceedings of the XV International Conference on Human Computer Interaction (INTERACCION 2014)

*DOI (link to publication from Publisher):*

[10.1145/2662253.2662263](https://doi.org/10.1145/2662253.2662263)

*Publication date:*

2014

*Document Version*

Early version, also known as pre-print

[Link to publication from Aalborg University](#)

*Citation for published version (APA):*

Manresa-Yee, C., Morrison, A., Larsen, J. V., & Varona, J. (2014). A Vibrotactile Interface to Motivate Movement for Children with Severe to Profound Disabilities. In *Proceedings of the XV International Conference on Human Computer Interaction (INTERACCION 2014)* [10] Association for Computing Machinery.  
<https://doi.org/10.1145/2662253.2662263>

### General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

### Take down policy

If you believe that this document breaches copyright please contact us at [vbn@aub.aau.dk](mailto:vbn@aub.aau.dk) providing details, and we will remove access to the work immediately and investigate your claim.

# A Vibrotactile Interface to Motivate Movement for Children with Severe to Profound Disabilities

Cristina Manresa-Yee  
Department of Mathematics  
and Computer Science  
Universitat de les Illes Balears  
Ctra. Valldemossa km 7.5  
07122, Palma, SPAIN  
cristina.manresa@uib.es

Ann Morrison, Jeppe V. Larsen  
Department of Architecture, Design  
and Media Technology,  
Aalborg University  
Sofieendalsvej 11, 9200, Aalborg SV,  
DENMARK  
{morrison, jvl}@create.aau.dk

Javier Varona  
Department of Mathematics  
and Computer Science  
Universitat de les Illes Balears  
Ctra. Valldemossa km 7.5  
07122, Palma, SPAIN  
xavi.varona@uib.es

## ABSTRACT

V-Sense is a vibrotactile interface that encourages children with severe or profound cognitive, sensory and physical impairments to move. The interface makes use of touch, in particular vibrations, as a supportive function to motivate users' actions. Specifically, we propose a vibrotactile interface on the arm and around the shoulder using the saltation perceptual illusion to induce movement of the corresponding joint. In this paper we describe the design principles of the interface and the proposed experimental design to evaluate it.

## Categories and Subject Descriptors

H.5.1 Multimedia Information Systems; H.5.2. User interfaces.

## General Terms

Design

## Keywords

Vibrotactile interface; children with special needs; interactive environment; user interface

## 1. INTRODUCTION

People with severe to profound developmental disabilities are often isolated and limited in their interactions with the surrounding world. Endeavors to improve their interaction potential and offer them more control over their environment supported by technology have been carried out [1][2][3].

In a previous work, we developed and evaluated SinaSense [3], which is a motion-based interface that serves as an educational application for children with severe to profound developmental disabilities that depend on others to interact with the environment. This interface makes use of computer vision to detect the body movements of the user by tracking a colored band, which in turn triggers meaningful outcomes from the system (music, images, videos and so on). An example of use of SinaSense is to attach the colored band to the user's wrist and while the user keeps his or her arm raised, music plays and it is

paused when the user lowers the arm.

The results of the evaluation with end-users for three months showed that by using SinaSense, children increased their intentional movement and the duration of the movement. However, while evaluating the system, we observed that the educational psychologist who conducted the evaluation assisted children physically and orally to help them to be aware of the reaction in the environment that their body motion was causing. Both this observation and the therapists' comments on the importance of touch with these users motivated this work.

We have designed V-Sense, a vibrotactile interface to complement SinaSense, which seeks to encourage and motivate the user to raise their arm using vibration cues. The aim of V-Sense is to reduce the need from the therapist for both physical and oral support.

In the following paper, we present the related works and our proposal for the design of the system.

## 2. RELATED WORK

Touch can be defined as the sensation elicited when the skin is subjected to mechanical, thermal, chemical or electrical stimuli. The sense of touch comprises two sub modalities: kinesthetic and cutaneous. The former provides information about the static and dynamic body postures and the latter provides awareness of the stimulation of the outer surface of the body [5]. In particular, vibration is a form of cutaneous stimulation, as it produces a distortion on the cutaneous surface [6].

In order to communicate information through the sense of touch by the application of pressure, vibration or force, haptic interfaces are used. These haptic interfaces can be wearable interfaces and they can be mounted on different devices for the users to wear such as glasses, gloves, watches, vests, pendants, caps, and so on. The use of vibrotactile information can be twofold: to provide feedback [7] or as a supportive function to motivate users' actions [8].

### 2.1 Vibrotactile interfaces and disability

Research on vibrotactile interfaces for disabled users has specially focused on visually-impaired users to help them in their interaction with the environment or with other people: to enhance navigation abilities [9][10], to interact with nearby objects [11], to present graphical information non-visually [12], to enrich interpersonal communication [13][14], to play with videogames [15][16][17], to teach choreographed dance [18] or to generate Braille on a mobile [19].

We also found studies addressing problems encountered by users with hearing impairments. In this case, vibrotactile interfaces are used to translate sounds (music, speech or environmental noises) into physical vibrations [20][21].

Very few works using vibrotactile information for interaction purposes and addressing users with cognitive impairments can be found in the literature. Knudsen et al. [22] presented a vibrotactile system for navigation support of people with mild cognitive impairment.

## 2.2 Interface and the saltation illusion

Saltation, or cutaneous rabbit, is a perceptual illusion, where a rapid vibrotactile pulse delivered first to one location and then to another on the skin produces the sensation of a virtual vibration between the two vibrators [23].

This illusion has been used in vibrotactile interfaces to motivate particular movements. Spelmezan et al. [24] defined tactile motion instructions as tactile feedback that communicates how to move the body, that is, they provided tactile motion instructions by mapping vibrotactile patterns to body motions (specifically for snowboarding). McDaniel et al. [25] proposed a framework, MOVEMENT (Mapping Of Vibrations to moveMENT), to use vibrotactile stimulation to incite the user to perform fundamental movements, that is, flexion, extension, abduction, adduction and rotation.

MacDaniel et al. [25] stated that all approaches to instruct motor skills through vibrotactile stimulations can be organized based on the level of abstraction of the vibrotactile-movement mapping: there is a continuous spectrum from no abstraction to high abstraction. On the end of no abstraction, there are for example those systems that use of vibrotactile stimulation to indicate a movement error. And at the other end of the spectrum, the high abstraction, the vibrotactile stimulation incites the user to perform a movement. Since the level of abstraction is high, users must recognize particular vibrotactile patterns of an already known set of movements.

In the experiments presented in these works, users interpreted the directionality of the vibration patterns as “pushing”/“pulling” or as a “follow me” instruction.

As far as we are aware, there are no studies that have used the saltation illusion to motivate movements in users with disabilities.

## 3. V-SENSE RATIONALE

Based on the saltation illusion and the characteristics of the users we designed a vibrotactile interface to motivate two kinds of arm/forearm movements:

- Elbow flexion: for children with very little movement who find difficulties lifting totally their arms (see Fig. 1 (a)).
- Shoulder flexion: for children capable of lifting their arms completely (see Fig. 1 (b)).

To design an intuitive interface, we considered the following issues [25]:

- Pattern of vibration: the vibrotactile pattern should exploit the effects of saltation.
- Direction of vibration: for example the push/pull or “follow me” metaphors [24].

- Location of vibration: it is intuitive to vibrate the skin close to the area where the movement is going to occur.

Furthermore, we have to take into account the three stages in the kinematic-vibrotactile mapping to facilitate motor learning [26]: (1) the design of the vibration signal to be applied to the skin; (2) the conceptual mapping of the perceived vibration signal to the movement it is intended to elicit or cue; and (3) the type of movement to be performed based on the cue.




Figure 1: (a) Elbow flexion (b) Shoulder flexion

### 3.1 Elbow flexion


The vibration motors should be placed on or near the muscle/joint/body part involved in the movement. For example, to flex and extend the elbow, the vibration motors could be placed on the bicep muscle or across the elbow joint. We follow the location used for elbow flexion/extension described in [25], as it has been tested with successful results (with users with no disabilities). Therefore, three vibration motors are set up in line on an arm band and placed on the bicep muscle above the elbow joint, as depicted in Fig. 2(a).

The vibrotactile stimulations will travel up to simulate the pull metaphor of the forearm. The pattern will consequently pulse the three vibrators (V1-V1-V1-V2-V2-V2-V3-V3-V3), where each vibration cue will be repeated as recommended by McDaniel et al. [25] for improved user perception. The burst will be of a 100 ms, with a 50 ms inter-burst interval, which is considered optimal to elicit saltation and has been successfully evaluated in the aforementioned works.

### 3.2 Shoulder flexion

Three vibration motors are set up on a shoulder pad embracing the shoulder as shown in Fig. 2(b). The vibrators could be placed on an armband on the biceps but closer to the shoulder than the ones used for the elbow flexion. However, we chose the first approach to completely differentiate it from the elbow flexion.

The pattern of vibration will be: V1-V1-V1-V2-V2-V2-V3-V3-V3 to motivate the arm lifting. Once again the burst duration of 100 ms is used, with a 50 ms inter-burst interval.



**Figure 2.** Localization of vibration motors for (a) elbow and (b) shoulder flexion

### 3.3 System implementation and lab testing

The interface uses an Arduino Mega microcontroller and the three vibrators are Precision Microdrives 310-103 Pico Vibe™ 10mm. Cables have been lengthened up to 2 meters to offer comfort and flexibility to the users when performing the movements. Further, a switch has been provided to trigger the vibrations whenever the therapist feels it is required.

The system is currently powered by a USB cable connected to a computer. The firmware stored on the microcontroller was developed using the Arduino development environment.

The interface was evaluated with users with no disabilities in a laboratory. We explained users how the system worked and then the system was set up, first the elbow interface and then the shoulder interface. The vibrations were triggered several times to observe the users reaction: if the vibrations were easy to feel, if movements were easy to carry out with the vibrators on or if the movement was intuitive, easy-to-learn and easy-to-remember.

The system proved to be an easy system to set up, with a comfortable and flexible interface for performing the movements. We observed that it was useful to hang the cable on the back rest of the chair, so that the user had more ease when raising the arm/forearm: it was lighter for the user as they did not have to lift all the cable and it was less cumbersome. Users reported having no trouble identifying the movement to perform (lifting the arm or forearm), as the location of the vibrators was on the region to move and directionality also improved the intuitiveness.


## 4. CONCLUSIONS AND FUTURE WORK

In a previous work, we designed and evaluated SinaSense, a motion-based interface that makes use of computer vision to detect the body movements, which in turn triggers meaningful outcomes from the system (music, images, videos and so on). The aim of the system was to offer the user more control over the environment and improve his or her interaction with it. Results were successful, but users needed physical and oral support from the therapist conducting the evaluation.

To avoid the physical assistance and to reduce the need for oral support, in this paper we have presented V-Sense, a wearable vibrotactile interface for children with severe to profound developmental disabilities. The interface exploits the saltation illusion to motivate users' actions, specifically, raising the arm or

forearm. We have described the design principles of the interfaces and a first working prototype has been developed (see Fig. 3) and evaluated successfully with users with no disabilities. Even if lab testing was carried out with successful results, it is very important to test a complete version with the intended end-users as their profile is totally different and they may present with sensory, physical and cognitive impairments.

The aim of the user evaluation will be to assess whether the use of vibrotactile information motivates the user's movement, increasing the number of times the user raises the arm or forearm autonomously.



**Figure 3.** The complete system: V-Sense and SinaSense

## 5. ACKNOWLEDGMENTS

We thank Tomeu Manresa, Ramon Mas and Pere Palmer for the technical help. This work was partially supported by Ajudes grup competitiu UGIVIA 28/2011 granted by the Govern de les Illes Balears, TIN12-35427 granted by the Gobierno de España, and by the EU funded project CultAR (FP7-ICT-2011-9 601139). C. Manresa-Yee also acknowledges the support of the mobility grant CAS12/00199, Programa José Castillejo granted by the Ministerio de Educación, Cultura y Deporte, Programa Nacional de Movilidad de Recursos Humanos del Plan Nacional de I-D+i 2008-2011, prorrogado por Acuerdo de Consejo de Ministros de 7 de octubre de 2011.

## 6. REFERENCES

- [1] Lancioni, G. E., O'Reilly, M. F. and Basili, G. 2001. Use of microswitches and speech output systems with people with severe/profound intellectual or multiple disabilities: a literature review. *Research in Developmental Disabilities*, 22, 1, 21-40.
- [2] Mauri, C., Solanas, A., Granollers, T., Bagés, J. and García, M. 2009. Interactive Therapeutic Multi-sensory Environment for Cerebral Palsy People. In *Proc. of the 12th IFIP TC 13 International Conf. on Human-Computer Interaction: Part II*.



- (Uppsala, Sweden). Springer-Verlag, Berlin, Heidelberg, 696-699.
- [3] Shih, C., Chang, M. and Shih, C. 2010. A limb action detector enabling people with multiple disabilities to control environmental stimulation through limb action with a Nintendo Wii Remote Controller. *Research in Developmental Disabilities*, 31, 5, 1047-1053.
  - [4] Manresa Yee, C., Muntaner, J. J. and Arellano, D. 2013. A motion-based interface to control environmental stimulation for children with severe to profound disabilities. In *Proc. CHI '13 Extended Abstracts on Human Factors in Computing Systems*. (Paris, France). ACM, New York, NY, USA, 7-12.
  - [5] Dahiya, R. S. and Valle, M. 2008. Tactile Sensing for Robotic Applications. In Rocha, J. G. and Lanceros-Mendez, S. eds. *Sensors: Focus on Tactile Force and Stress Sensors*. InTech, 189.
  - [6] Gandhi, M., Sesek, R., Tuckett, R. and Bamberg, S. 2011. Progress in vibrotactile threshold evaluation techniques: a review. *Journal of Hand Therapy*, 24, 3, 240-55.
  - [7] Lindeman, R. W., Yanagida, Y., Hosaka, K. and Abe, S. 2006. The TactaPack: A Wireless Sensor/Actuator Package for Physical Therapy Applications. In *Proc. of Haptic Interfaces for Virtual Environment and Teleoperator Systems*, 337-341
  - [8] Spelmezan, D., Jacobs, M., Hilgers, A. and Borchers, J. 2009. Tactile Motion Instructions for Physical Activities. In *Proc. of the SIGCHI Conf. on Human Factors in Computing Systems*. (Boston, MA, USA). ACM, New York, NY, USA, 2243-2252.
  - [9] Ghiani, G., Leporini, B. and Paternó F. 2009. Vibrotactile Feedback to Aid Blind Users of Mobile Guides. *Journal of Visual Languages and Computing*, Multimodal Interaction through Haptic Feedback , 20, 5, 305-317.
  - [10] Uchiyama, H., Covington, M. A. and Potter, W. D. 2008. Vibrotactile Glove guidance for semi-autonomous wheelchair operations. In *Proc. of the 46th Annual Southeast Regional Conference (ACM-SE 46)*. ACM, New York, NY, USA, 336-339.
  - [11] Bahram, S., Chakraborty, A., Ravindran, S. and Amant, R. 2013. Intelligent Interaction in Accessible Applications. In *A Multimodal End-2-End Approach to Accessible Computing Human-Computer Interaction Series*, Springer, 93-117.
  - [12] Giudice, N. A., Palani, H. P., Brenner, E. and Kramer, K. M. 2012. Learning Non-visual Graphical Information Using a Touch-based Vibro-audio Interface. In *Proc. of the 14th International ACM SIGACCESS Conf. on Computers and Accessibility*. (Boulder, Colorado, USA). ACM, New York, NY, USA, 103-110
  - [13] Krishna, S., Bala, S., McDaniel, T., McGuire, S. and Panchanathan, S. 2010. VibroGlove: An Assistive Technology Aid for Conveying Facial Expressions. In *Proc. CHI '10 Extended Abstracts on Human Factors in Computing Systems*. (Atlanta, Georgia, USA). ACM, New York, NY, USA, 3637-3642.
  - [14] Réhman, S., Liu, L. and Li, H. 2008. Vibrotactile Rendering of Human Emotions on the Manifold of Facial Expressions, *J. of Multimedia*, vol. 3, 18-25
  - [15] Yuan, B. and Folmer, E. 2008. Blind Hero: Enabling Guitar Hero for the Visually Impaired. In *Proc. of the 10th International ACM SIGACCESS Conf. on Computers and Accessibility*. (Halifax, Nova Scotia, Canada). ACM, New York, NY, USA, 169-176.
  - [16] Morelli, T., Foley, J., Folmer, E. 2010. Vi-bowling: a tactile spatial exergame for individuals with visual impairments, In *Proc. of the 12th international ACM SIGACCESS conference on Computers and accessibility*, October 25-27, 2010, Orlando, Florida, USA
  - [17] Morelli, T., Foley, J., Columna, L., Lieberman, L., and Folmer, E. VI-Tennis: a vibrotactile/audio exergame for players who are visually impaired, In *Proc. of Foundations of Digital Interactive Games* (Monterey, California, 2010).
  - [18] Rosenthal, J., Edwards, N., Villanueva, D., Krishna, S., McDaniel, T. and Panchanathan, S. 2011. Design, Implementation, and Case Study of a Pragmatic Vibrotactile Belt. *IEEE Transactions on Instrumentation and Measurement*, 60, 1, 114-125.
  - [19] Chandrika Jayant, Christine Acuario, William Johnson, Janet Hollier, and Richard Ladner. 2010. V-braille: haptic braille perception using a touch-screen and vibration on mobile phones. In *Proc. of the 12th international ACM SIGACCESS conference on Computers and accessibility (ASSETS '10)*. ACM, New York, NY, USA, 295-296
  - [20] Nanayakkara, S., Taylor, E., Wyse, L. and Ong, S. H. 2009. An Enhanced Musical Experience for the Deaf: Design and Evaluation of a Music Display and a Haptic Chair. In *Proc. of the SIGCHI Conference on Human Factors in Computing Systems*. (Boston, MA, USA). ACM, New York, NY, USA, 337-346.
  - [21] Yao, L., Shi, Y., Chi, H., Ji, X. and Ying, F. 2010. Music-touch Shoes: Vibrotactile Interface for Hearing Impaired Dancers. In *Proc. of the Fourth International Conf. on Tangible, Embedded, and Embodied Interaction*. (Cambridge, Massachusetts, USA). ACM, New York, NY, USA, 275-276.
  - [22] Knudsen, L., Morrison, A. and Andersen, J. H. 2011. Design of vibrotactile navigation displays for elderly with memory disorders. *Report AAU*.
  - [23] Geldard, F. A. and Sherrick, C. E. 1972. The Cutaneous "Rabbit": A Perceptual Illusion. *Science*, 178, 4057, 178-179.
  - [24] Spelmezan, D., Hilgers, A. and Borchers, J. A. 2009. Language of Tactile Motion Instructions. In *Proc. of the 11th International Conf. on Human-Computer Interaction with Mobile Devices and Services*. (Bonn, Germany). ACM, New York, NY, USA, 29:1-29:5.
  - [25] McDaniel, T., Villanueva, D., Krishna, S. and Panchanathan, S. 2010. MOVeMENT: A framework for systematically mapping vibrotactile stimulations to fundamental body movements. In *Proc. Haptic Audio-Visual Environments and Games*, IEEE, 1-6
  - [26] McDaniel, T., Goldberg M., Villanueva D., Viswanathan LN, Panchanathan S, 2011, Motor learning using a kinematic-vibrotactile mapping targeting fundamental movements. In *Proc. of the 19th ACM international conference on Multimedia (MM '11)*, Scottsdale, Arizona, 2011